

دعوة لبيع

مدرسة الملك سعود: MNU-CA-FM/2024/ 36

مدرسة الملك سعود، في إطار تنفيذ أعمال الصيانة والتطوير في مبنى الإدارة، تودع لبيع المواد والمنتجات التالية:

مواصفات ومواصفات المواد

في دعوة لبيع المواد والمنتجات التالية:

مواصفات ومواصفات المواد

في دعوة لبيع المواد والمنتجات التالية، بتاريخ 19 و 20 من شهر ربيع الثاني 1446 هـ الموافق 11:30 صباحاً 2024

إرسال الطلبات إلى: procurement.noticeboard@mnu.edu.mv أو facilitiesmanagement@mnu.edu.mv

للمزيد من التفاصيل، يرجى الاتصال بمركز معلومات ودراسات مدرسة الملك سعود، هاتف: 3345134، 3345192

مواصفات ومواصفات المواد

• في دعوة لبيع المواد والمنتجات التالية، بتاريخ 19 و 20 من شهر ربيع الثاني 1446 هـ الموافق 11:30 صباحاً 2024

إرسال الطلبات إلى: procurement.noticeboard@mnu.edu.mv أو facilitiesmanagement@mnu.edu.mv

16 من شهر ربيع الثاني 2024



SBLOCK 5	Fire Extinguisher CO2	2 KG	Outdated and needs to be renewed	Needle within the green zone	Pin in not usable condition	No need to paint
SBLOCK 6	Fire Extinguisher CO2	2 KG	Outdated and needs to be renewed	Needle within the green zone	Pin in not usable condition	No need to paint
SBLOCK 7	Fire Extinguisher CO2	2 KG	Outdated and needs to be renewed	Needle within the green zone	Pin in place and intact	No need to paint
SBLOCK 8	Fire Extinguisher CO2	2 KG	Outdated and needs to be renewed	Needle within the green zone	Pin in place and intact	No need to paint
SBLOCK 9	Fire Extinguisher CO2	2 KG	Outdated and needs to be renewed	Needle within the green zone	Pin in place and intact	No need to paint
SBLOCK 10	Fire Extinguisher CO2	2 KG	Outdated and needs to be renewed	Needle within the green zone	Pin in place and intact	No need to paint
SBLOCK 11	Fire Extinguisher CO2	2 KG	Outdated and needs to be renewed	Needle within the green zone	Pin in place and intact	No need to paint
SBLOCK 12	Fire Extinguisher CO2	2 KG	Outdated and needs to be renewed	Needle within the green zone	Pin there but not sure of the safety status	No need to paint
SBLOCK 13	Fire Extinguisher CO2	2 KG	Outdated and needs to be renewed	Needle within the green zone	Pin there but not sure of the safety status	No need to paint
SBLOCK 14	Fire Extinguisher CO2	2 KG	Outdated and needs to be renewed	Needle within the green zone	Pin there but not sure of the safety status	No need to paint
SBLOCK 15	Fire Extinguisher CO2	2 KG	Outdated and needs to be renewed	Needle within the green zone	Pin there but not sure of the safety status	No need to paint
SBLOCK 16	Fire Extinguisher CO2	2 KG	Outdated and needs to be renewed	Needle within the green zone	Pin in not usable condition	No need to paint
SBLOCK 17	Fire Extinguisher CO2	2 KG	Outdated and needs to be renewed	Needle within the green zone	Pin in place and intact	No need to paint
SBLOCK 18	Fire Extinguisher CO2	2 KG	Outdated and needs to be renewed	Needle within the green zone	Pin in place and intact	No need to paint
SBLOCK 19	Fire Extinguisher CO2	2 KG	Outdated and needs to be renewed	Needle within the green zone	Pin there but not sure of the safety status	No need to paint
SBLOCK 20	Fire Extinguisher CO2	2 KG	Outdated and needs to be renewed	Needle within the green zone	Pin there but not sure of the safety status	No need to paint
SBLOCK 21	Fire Extinguisher CO2	2 KG	Outdated and needs to be renewed	Needle within the green zone	Pin there but not sure of the safety status	No need to paint

SBLOCK 39	Fire Extinguisher CO21	2 KG	Outdated and needs to be renewed	Needle within the green zone	Pin there but not sure of the safety status	No need to paint
SBLOCK 40	Fire Extinguisher Dry Powder	4.5 KG	Outdated and needs to be renewed	Needle within the green zone	Pin there but not sure of the safety status	No need to paint
SBLOCK 41	Fire Extinguisher Dry Powder	4.5 KG	Outdated and needs to be renewed	Needle within the green zone	Pin there but not sure of the safety status	No need to paint
SBLOCK 42	Fire Extinguisher Dry Powder	4.5 KG	Outdated and needs to be renewed	Needle within the green zone	Pin there but not sure of the safety status	No need to paint
SBLOCK 43	Fire Extinguisher Dry Powder	4.5 KG	Outdated and needs to be renewed	Needle within the green zone	Pin there but not sure of the safety status	No need to paint
SBLOCK 44	Fire Extinguisher Dry Powder	4.5 KG	Outdated and needs to be renewed	Needle within the green zone	Pin there but not sure of the safety status	No need to paint
SBLOCK 45	Fire Extinguisher Dry Powder	4.5 KG	Outdated and needs to be renewed	Needle within the green zone	Pin there but not sure of the safety status	No need to paint
SBLOCK 46	Fire Extinguisher Dry Powder	4.5 KG	Outdated and needs to be renewed	Needle within the green zone	Pin there but not sure of the safety status	No need to paint